



Nashik Municipal Corporation, Nashik

STP Outlet Water Parameter

Date	7.5 MLD Panchak STP		21 MLD Panchak STP		32 MLD Panchak STP		20 MLD Chehedi STP		22 MLD Chehedi STP		40 MLD Agartakli STP		70 MLD Agartakli STP		52 MLD Tapovan STP		78 MLD Tapovan STP		18 MLD Gangapur STP		32 MLD Pimpalgaon khamb STP	
	COD	BOD	COD	BOD	COD	BOD	COD	BOD	COD	BOD	COD	BOD	COD	BOD	COD	BOD	COD	BOD	COD	BOD	COD	BOD
24-Apr-23	32.00	8.00	36.00	11.00	30.00	9.00	33.00	11.00	48.00	17.00	44.00	14.00	56.00	18.00	45.00	13.00	50.00	15.00	32.00	4.50	20.96	3.79
25-Apr-23	34.00	10.00	39.00	12.00	33.00	10.00	35.00	10.00	46.00	16.00	40.00	13.00	50.00	16.00	47.00	14.00	51.00	16.00	34.00	4.50	21.52	3.30
26-Apr-23	38.00	16.00	42.00	18.00	34.00	9.00	34.00	9.00	43.00	13.00	46.00	15.00	58.00	19.00	50.00	15.00	48.00	15.00	30.00	4.20	20.77	3.84
27-Apr-23	36.00	11.00	40.00	12.00	32.00	8.00	27.00	8.00	40.00	12.00	44.00	15.00	48.00	16.00	49.00	14.00	50.00	12.00	38.00	4.50	18.04	3.74
28-Apr-23	33.00	11.00	35.00	10.00	29.00	8.00	32.00	11.00	47.00	17.00	54.00	17.00	52.00	17.00	51.00	15.00	49.00	14.00	32.00	4.30	22.29	3.82
29-Apr-23	31.00	9.00	45.00	14.00	34.00	11.00	37.00	10.00	45.00	15.00	50.00	16.00	50.00	15.00	43.00	12.00	47.00	12.00	30.00	4.50	21.62	3.62
30-Apr-23	29.00	9.00	43.00	13.00	28.00	9.00	29.00	7.00	38.00	11.00	48.00	15.00	60.00	19.00	48.00	14.00	49.00	14.00	32.00	4.20	20.68	3.64